



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Brunswick St 150, Fitzroy
150 Brunswick St Fitzroy
Contract No: P3511

Callouts: 22246

Date of Call: 09-11-2018 11:59:51
Time of Arrival: 09-11-2018 12:33:00
Rectification Time: 09-11-2018 13:05:00
Time of Departure: 09-11-2018 13:19:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Button/Indicator Not Working

For Lift(s): 2

For Floor(s): 7

Call Description: level 7 lift button not working

Order Number: 007050

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: All buttons working correctly. Possibly customer had an issue with security fob not unlocking designated floor.

Part Required: No Parts Required

Service Technician

Marek Torrico

Report Customer

#