



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
03 9687 9099
info@unitedlifts.com.au

Customer Details:

William Angliss Institute (Building D - 555 La Trobe St)
555 La Trobe St Melbourne (Building D)
Contract No: P3175

Maintenance ID:

Date of Call: 16-10-2018
Time of Arrival: 10:27:00
Time of Departure: 15:29:00

Maintenance Details

Maintenance Description: Service visit

Maintenance Task	1	2	3
Contact Building Rep. Check Ride & Appointments.	Y	Y	Y
Clean out controller ad check operation of various parts.	Y	Y	Y
Check car door operator and associated equipment.	Y	Y	Y
Clean & check landing door equipment	Y	Y	Y
Check all safety switches, limits in lift well	Y	Y	Y
Check pit equipment and check water for pit	Y	Y	Y
Check trailer flexes, attachments running clearance	Y	Y	Y
Test Lift Communications	Y	Y	Y

Service Technician

Gavin Pedlar

Customer Email

AleyshaV@angliss.edu.au