



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Metro Mernda Station
0 Bridge Inn Road South Morang
Contract No: W3696

Callouts: 22399

Date of Call: 26-11-2018 13:24:09
Time of Arrival: 27-11-2018 8:36:00
Rectification Time: 27-11-2018 10:38:00
Time of Departure: 27-11-2018 11:26:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): stuck on ground floor

Call Description: stuck on platform level. doors are closed and states \"not in use\"r\nSite contact: Vikram 96102943

Order Number: 659491

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Found series of safetys tripped aswell as water logged stop button in pit. Reset each safety and adjusted to suit. Investigated each cause. Water logged safety circuit also tripping circuit breaker. Performed safety check and investigated where water is entering shaft.

Part Required: No Parts Required

Service Technician

Marek Torrico

Report Customer

metro