



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Glen Eira Town Hall

0 Corner Hawthorn Rd & Glen Eira Rd Caulfield

Contract No: P3399

Callouts: 22463

Date of Call: 03-12-2018 10:54:30

Time of Arrival: 03-12-2018 0:30:00

Rectification Time: 03-12-2018 15:15:00

Time of Departure: 03-12-2018 3:25:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 5

For Floor(s): 1

Call Description: Library lift is out of order

Order Number: 67

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Found lift 000 on top standing. Found limit switch in shaft with high resistance contact, replace and test - ok.

Part Required: No Parts Required

Service Technician

Kevin Wilkins

Report Customer

.