



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

The Australian Ballet School
2 Kavanagh St Southbank
Contract No: P3524

Callouts:

Date of Call: 15-11-2018 15:30:00
Time of Arrival: 15-11-2018 16:20:00
Rectification Time: 15-11-2018 17:00:00
Time of Departure: 15-11-2018 17:00:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Doors Open

For Lift(s): 2

For Floor(s): 3

Call Description: Lift has doors open

Order Number: 0

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): Reset Door Operator

Work Description: Doors not closing properly, speed wrong and seemed to be at times not seeing close limit.
Reset and re learn operator and check locks for snatching and good make.

Part Required: No Parts Required

Service Technician

Zane Tregurtha

Report Customer

0