



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Patterson Rd 60-66, Bentleigh
60-66 Patterson Rd Bentleigh
Contract No: P3247

Callouts: 22776

Date of Call: 04-01-2019 8:58:57
Time of Arrival: 04-01-2019 9:55:00
Rectification Time: 04-01-2019 10:25:00
Time of Departure: 04-01-2019 10:29:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Playing Up

For Lift(s): 1

For Floor(s): 0

Call Description: Lift settings may have been changed recently. No sensor activated to reopen doors if they are obstructed

Order Number: 0

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Light ray controll box failed.\r\nReplace controll box and test light ray operation, tested ok.

Part Required: No Parts Required

Service Technician

Zane Tregurtha

Report Customer

Nicole Ting 0403 276 901