



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Elizabeth St 65, Melbourne
65 Elizabeth St Melbourne
Contract No: P3131

Callouts:

Date of Call: 15-12-2018 13:58:00
Time of Arrival: 15-12-2018 14:30:00
Rectification Time: 15-12-2018 15:10:00
Time of Departure: 15-12-2018 15:15:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): 5

Call Description: reported lift out of order

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): Running On Arrival

Work Action (CORRECTION): See Work description

Work Description: lift running on arrival \r\nchecked all floors\r\nlift not calling from level 5 landing panel,\r\nchecked button found fault on main board for level 5 landing, put sign up on level 5 button panel to use level 4 button,\r\nlift running.

Part Required: No Parts Required

Service Technician

Robert Pelle

Report Customer

Dan