



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Albert Redevelopment
140 Albert Road South Melbourne
Contract No: W3688

Callouts: 22584

Date of Call: 13-12-2018 8:20:00
Time of Arrival: 13-12-2018 8:40:00
Rectification Time: 13-12-2018 10:15:00
Time of Departure: 13-12-2018 10:15:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 2

For Floor(s): b1

Call Description: tripped out. panel not showing anything

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Water coming down from top of the shaft. Lift shut down till issue is rectified

Part Required: No Parts Required

Service Technician

Brad Stellini

Report Customer

David Ellis - 0414 324 894