



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
03 9687 9099
info@unitedlifts.com.au

Customer Details:

Wells St 60, Frankston
60 Wells St Frankston
Contract No: P3307

Maintenance:

Date of Call: 26-11-2018
Time of Arrival: 9:00:00
Time of Departure: 9:45:00

Maintenance Details

Maintenance Description: Reported that lift is hunting for floor level at top floor when loaded with around 10 people. Unable to test condition, no faults found. Reported that lift intermittently opens doors on L4 while secured without a call, no faults found in log further investigation required.

Maintenance Task	1	2
Contact Building Rep. Check Ride & Appointments.	Y	Y
Clean & Check all M/R Equipment	Y	Y
Clean out controller and check operation of various parts.	Y	Y
Check tuning adjustments	Y	Y
Check car door operator and associated equipment.	Y	Y
Clean & check landing door equipment	Y	Y
check brake operation rope brake and associated equipment	Y	Y
Check pit equipment and check water for pit	Y	Y
Test Emergency Light Unit	Y	Y
Test Lift Communications	Y	Y

Service Technician

Kevin Wilkins

Customer Email

ross@wolfstep.com.au