



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Carlisle St 17, St Kilda
17 Carlisle St St Kilda
Contract No: P3417

Callouts ID: 21978

Date of Call: 12-10-2018 9:54:00
Time of Arrival: 12-10-2018 10:17:00
Rectification Time: 12-10-2018 10:27:00
Time of Departure: 12-10-2018 10:40:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): g

Call Description: lift is out of order

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): Running On Arrival

Work Action (CORRECTION): See Work description

Work Description: Lift reported ooo on ground floor with doors open, running on arrival but found 2 dollar coin stuck in door track, removed and test lift operation

Part Required: No Parts Required

Service Technician

Dwain Sanderson

Report Customer

wayne