



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Nicholson Street 141, Carlton
141 Nicholson St Carlton
Contract No: P3118

Callouts:

Date of Call: 07-11-2018 17:20:00
Time of Arrival: 07-11-2018 17:45:00
Rectification Time: 07-11-2018 18:20:00
Time of Departure: 07-11-2018 18:45:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): 10

Call Description: L1 OOO

Order Number: 15449

DESCRIPTION OF WORK

Fault Found (CAUSE): Rope Brake Tripped

Work Action (CORRECTION): See Work description

Work Description: Strip clean and reset rope brake

Part Required: No Parts Required

Service Technician

Phil Dodsworth

Report Customer

yes