



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Nicholas Building
37 Swanston St Melbourne
Contract No: 3265

Callouts ID:

Date of Call: 20-10-2018 12:59:00
Time of Arrival: 20-10-2018 14:45:00
Rectification Time: 20-10-2018 15:24:00
Time of Departure: 20-10-2018 15:45:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 4

For Floor(s): g

Call Description: Lift ooo on ground with doors open

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): Obstruction in doors

Work Action (CORRECTION): Remove Object From Doors

Work Description: Lift 4 ooo on g with doors open\r\nLift recorded 54 fault \r\nFound ground floor door tracks filled with dirt and rubbish\r\nRemoved dirt and tested

Part Required: No Parts Required

Service Technician

Dwain Sanderson

Report Customer

.