



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

Derby St 56, Kensington  
56 Derby St Kensington  
Contract No: P3419

## Callouts:

Date of Call: 24-11-2018 13:33:00  
Time of Arrival: 24-11-2018 14:20:00  
Rectification Time: 24-11-2018 15:00:00  
Time of Departure: 24-11-2018 15:10:00

### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** O.O.O

**For Lift(s):** 2

**For Floor(s):** 12

**Call Description:** reported lift 2 stuck on level 12 doors open nobody stuck inside.

**Order Number:** .

### DESCRIPTION OF WORK

**Fault Found (CAUSE):** Obstruction in doors

**Work Action (CORRECTION):** Remove Object From Doors

**Work Description:** lift 2 stuck on level 12, door close protection error,\r\nfound obstruction in landing door track\r\nremoved obstruction (ball bearing) checked landing doors on level 12 returned lift back to service checked operation ok.

**Part Required:** No Parts Required

**Service Technician**

Robert Pelle

**Report Customer**

yusef