



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Toomah Community Centre
18 Golden Green Street Pakenham
Contract No: P3488

Callouts: 22654

Date of Call: 18-12-2018 11:09:02
Time of Arrival: 18-12-2018 13:15:00
Rectification Time: 18-12-2018 13:20:00
Time of Departure: 18-12-2018 13:45:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): G

Call Description: lift is out of order on ground floor

Order Number: 25938

DESCRIPTION OF WORK

Fault Found (CAUSE): Power Failure

Work Action (CORRECTION): Reset Control System

Work Description: Found lift shutdown by Drive with Power off fault causing drive block. Reset controls and test incoming mains supply - ok. Return to service test operation - ok.

Part Required: No Parts Required

Service Technician

Kevin Wilkins

Report Customer

.