

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 1300161740 info@unitedlifts.com.au

Service Address:

Centre for Adult Education / Flinders Lane City Library 253 Flinders Lane Melbourne

Contract No: P3388

Callouts ID: 22069

Date of Call: 23-10-2018 8:50:00 Time of Arrival: 23-10-2018 9:00:00 Rectification Time: 23-10-2018 21:55:00 Time of Departure: 23-10-2018 10:10:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 2,3

For Floor(s): 1&g

Call Description: lifts are out of order

Order Number: x

DESCRIPTION OF WORK

Fault Found (CAUSE): Error Log Fault

Work Action (CORRECTION): Reset Control System

Work Description: MCB error on both lifts reset control boards and tested

Part Required: No Parts Required

Service Technician Report Customer

Graeme Gathercole