



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:
Trak Centre
443 Toorak Rd Toorak
Contract No: P3166

Callouts: 22247

Date of Call: 09-11-2018 12:45:50
Time of Arrival: 09-11-2018 14:10:00
Rectification Time: 09-11-2018 14:25:00
Time of Departure: 14-11-2018 14:35:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Playing Up

For Lift(s): 3

For Floor(s): g

Call Description: disable lift stopping above floor level

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): Faulty Contactor

Work Action (CORRECTION): See Work description

Work Description: Replaced faulty up contactor as it was getting stuck up and driving over the top \r\nTested lift operation

Part Required: No Parts Required

Service Technician

Dwain Sanderson

Report Customer

Eddie 0401 030 480