



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Bay Rd 294, Cheltenham
294 Bay Rd Cheltenham
Contract No: P3437

Callouts: 22027

Date of Call: 18-10-2018 15:23:00
Time of Arrival: 09-11-2018 9:30:00
Rectification Time: 09-11-2018 9:45:00
Time of Departure: 09-11-2018 9:50:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 2

For Floor(s): 2

Call Description: one of the lifts is not working, it appears to be stuck at level 2 and wont open

Order Number: AU00623963

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Found drive not working on the day of initial callout, sent drive to be repaired. Collected drive 9/11/18 and installed on site. Test operation -

Part Required: V3F16L inverter module.

Service Technician

Kevin Wilkins

Report Customer

.