

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 1300161740 info@unitedlifts.com.au

Service Address:
Wellington Street 240, Collingwood
240 Wellington Street Collingwood
Contract No: 3700

Callouts:

Date of Call: 03-01-2019 23:17:00 Time of Arrival: 03-01-2019 23:58:00 Rectification Time: 04-01-2019 1:20:00 Time of Departure: 04-01-2019 1:30:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 2

For Floor(s): 19

Call Description: reported lift stuck on level 19 with doors open.

Order Number: 16418

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Found obstruction in landing door track \r\nremoved obstruction checked landing door operation and lock adjustment tested ok.

Part Required: No Parts Required

Service Technician Report Customer

Robert Pelle Mohammed