

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 1300161740 info@unitedlifts.com.au

Service Address:

Melbourne Water
87-89 Millers Road Brooklyn
Contract No: B3747

Callouts:

Date of Call: 29-11-2018 11:50:00 Time of Arrival: 29-11-2018 12:05:00 Rectification Time: 29-11-2018 13:30:00 Time of Departure: 29-11-2018 15:15:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 3

For Floor(s): g

Call Description: Ooo

Order Number: 4082522

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Ooo on ground level below bottom floor\r\nCheck tape reader guides and clean sensors\r\nTest operation

Part Required: No Parts Required

Service Technician

Report Customer

Matt Grieger