



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

1-3 Railway Place
1-3 Railway Place Cremorne
Contract No: 3572

Callouts: 22542

Date of Call: 10-12-2018 13:11:50
Time of Arrival: 10-12-2018 13:25:00
Rectification Time: 10-12-2018 13:30:00
Time of Departure: 10-12-2018 14:10:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): S.W.P

For Lift(s): 1

For Floor(s): ground floor

Call Description: SWP

Order Number: *

DESCRIPTION OF WORK

Fault Found (CAUSE): Obstruction in doors

Work Action (CORRECTION): See Work description

Work Description: Found nail in door track. Removed. Cleaned all locks, checked ground floor locks, checked doors for freedom of movement. All tested ok. Returned to service.

Part Required: No Parts Required

Service Technician

Nathan Downton

Report Customer

0447255566