



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

Glenhuntly Rd 242, Elsternwick  
242 Glenhuntly Rd Elsternwick  
Contract No: P3449

## Callouts:

Date of Call: 08-12-2018 15:34:00  
Time of Arrival: 08-12-2018 16:25:00  
Rectification Time: 08-12-2018 17:00:00  
Time of Departure: 08-12-2018 17:30:00

### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** O.O.O

**For Lift(s):** 2

**For Floor(s):** -1

**Call Description:** Ooo

**Order Number:**

### DESCRIPTION OF WORK

**Fault Found (CAUSE):** See Work Description

**Work Action (CORRECTION):** See Work description

**Work Description:** Lift ooo approx 1 ft above basement level\r\nSafety and lock circuits ok \r\nNo direction contactors in\r\nCheck and test direction circuit \r\n\r\ncleared during testing\r\n\r\nTest operation

**Part Required:** No Parts Required

**Service Technician**

Matt Grieger

**Report Customer**

costa