



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Brunswick St 150, Fitzroy
150 Brunswick St Fitzroy
Contract No: P3511

Callouts ID: 22075

Date of Call: 23-10-2018 12:49:42
Time of Arrival: 24-10-2018 8:40:00
Rectification Time: 24-10-2018 10:40:00
Time of Departure: 24-10-2018 10:49:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Button/Indicator Not Working

For Lift(s): 1,2

For Floor(s): G

Call Description: lift buttons are missing, not working and broken on various levels

Order Number: 007016

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Lift 1 door open button replaced
Lift 1 level 6 button replaced
Level 5 up button replaced
Level 3 up button replaced
Level 3 down button replaced
Level 2 down button replaced

Part Required: 6 x shindler buttons replaced as per request

Service Technician

Marek Torrico

Report Customer

#