

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 1300161740 info@unitedlifts.com.au

Service Address:
Bowen Cres 3, Melbourne
3 Bowen Cres Melbourne
Contract No: P3031

Callouts ID: 22037

Date of Call: 19-10-2018 10:30:43 Time of Arrival: 19-10-2018 11:00:00 Rectification Time: 19-10-2018 23:10:00 Time of Departure: 19-10-2018 12:00:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): S.W.P

For Lift(s): 3

For Floor(s): 4

Call Description: SWP

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: S.W.P, released passenger\r\nArmature over current fault, checked main and break contact\'s, checked aramture brushes\r\nRan and tested

Part Required: No Parts Required

Service Technician Report Customer

Brad Stellini .