



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
03 9687 9099
info@unitedlifts.com.au

Customer Details:

Gurewicz Building, Moshin Building
10-12 Balaclava Rd St Kilda
Contract No: B3376

Maintenance:

Date of Call: 29-11-2018
Time of Arrival: 14:45:00
Time of Departure: 15:20:00

Maintenance Details

Maintenance Description: Routine maintenance

Maintenance Task	1
Contact Building Rep. Check Ride & Appointments.	Y
Test all car safeties	Y
Clean & Check all M/R Equipment	Y
Clean out controller ad check operation of various parts.	Y
Check tuning adjustments	Y
Check car door operator and associated equipment.	Y
Clean & check landing door equipment	Y
Check and adjust car & cwt guide shoes	Y
Check all safety switches, limits in lift well	Y
check brake operation rope brake and associated equipment	Y
Check pit equipment and check water for pit	Y
Fire Service Operation Test	Y
Test Emergency Light Unit	Y
Test Lift Communications	Y

Service Technician

Kevin Wilkins

Customer Email

justin.harris@yeshivahcentre.org