



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:
Queen St 341
341 Queen Street Melbourne
Contract No: P3719

Callouts ID: 22079

Date of Call: 23-10-2018 15:17:40
Time of Arrival: 23-10-2018 16:10:00
Rectification Time: 23-10-2018 16:30:00
Time of Departure: 23-10-2018 16:37:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 3

For Floor(s): 9

Call Description: passenger was stuck in lift. Now out of order

Order Number: x

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Checked door lock and landing doors. Checked safety circuit and controller relays..Reset controller. Checked lift operation.

Part Required: No Parts Required

Service Technician

Gavin Pedlar

Report Customer

x