



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Civic Centre City of Whittlesea
25 Ferres Blvd South Morang
Contract No: S3042

Callouts: 22300

Date of Call: 15-11-2018 13:09:56
Time of Arrival: 16-11-2018 8:30:00
Rectification Time: 16-11-2018 9:30:00
Time of Departure: 16-11-2018 10:30:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Button/Indicator Not Working

For Lift(s): Civic Centre

For Floor(s): basement

Call Description: lights & sound in lift is not working, level announcement not working

Order Number: 916695

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Lift halo light replaced. No annunciator or brail is fitted to this lift and is required. Will quote to install annunciator and buttons with brail requested.

Part Required: 2 x 36 w halo fluorescent light

Service Technician

Marek Torrico

Report Customer

#