



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Metro Westall
Metro Westall Station Clayton
Contract No: P3588

Callouts:

Date of Call: 20-11-2018 17:46:00
Time of Arrival: 20-11-2018 18:55:00
Rectification Time: 20-11-2018 20:00:00
Time of Departure: 20-11-2018 20:25:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): Lift 2

For Floor(s): G

Call Description: Lift no.2 out of order.

Order Number: x

DESCRIPTION OF WORK

Fault Found (CAUSE): Faulty Relay

Work Action (CORRECTION): Replace/Repair Relay or Contactor

Work Description: Phase failure relay faulty. Replaced same.

Part Required: Phase failure relay.

Service Technician

Gavin Pedlar

Report Customer

x