



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Box Hill Library
1038 Whitehorse Rd Box Hill
Contract No: 3471 - B076

Callouts: 22230

Date of Call: 08-11-2018 10:08:56
Time of Arrival: 08-11-2018 11:00:00
Rectification Time: 08-11-2018 11:25:00
Time of Departure: 08-11-2018 11:34:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): S.W.P

For Lift(s): 1

For Floor(s): *

Call Description: swp

Order Number: *

DESCRIPTION OF WORK

Fault Found (CAUSE): Door Operator Fault

Work Action (CORRECTION): Reset Door Operator

Work Description: Passenger out 10 mins after call placed. \r\nFound door operator fault. Reset operator, returned to service. Tested ok.

Part Required: No Parts Required

Service Technician

Nathan Downton

Report Customer

*