



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

Altona St 72, Kensington  
72 Altona St Kensington  
Contract No: P3426

## Callouts:

Date of Call: 20-12-2018 8:10:00  
Time of Arrival: 20-12-2018 8:50:00  
Rectification Time: 20-12-2018 9:20:00  
Time of Departure: 20-12-2018 9:40:00

### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** O.O.O

**For Lift(s):** 2

**For Floor(s):** 5

**Call Description:** Lift ooo

**Order Number:** .

### DESCRIPTION OF WORK

**Fault Found (CAUSE):** Door Lock Faulty

**Work Action (CORRECTION):** Adjust Doors/Locks

**Work Description:** Lock fly on lv 5. Adjust LH lock contact.

**Part Required:** No Parts Required

**Service Technician**

mat tehan

**Report Customer**

.