

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 1300161740 info@unitedlifts.com.au

Service Address:

Centre for Adult Education / Flinders Lane City Library 253 Flinders Lane Melbourne Contract No: P3388

Callouts ID: 22093

Date of Call: 24-10-2018 15:28:16 Time of Arrival: 24-10-2018 15:50:00 Rectification Time: 24-10-2018 16:00:00 Time of Departure: 24-10-2018 16:30:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): S.W.P

For Lift(s): 2

For Floor(s): 2-3

Call Description: person stuck in lift

Order Number: x

DESCRIPTION OF WORK

Fault Found (CAUSE): Error Log Fault

Work Action (CORRECTION): Reset Control System

Work Description: Reset to release passenger fault cleared, checked lift ran normally

Part Required: No Parts Required

Service Technician Report Customer

Graeme Gathercole Elly 0401 519 945