



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Central Shopping Center

Cnr Crn 13-15 Lake Street & 218-222 Caroline Springs Boulevard Caroline Springs

Contract No: P3712

Callouts: 22404

Date of Call: 26-11-2018 16:11:37

Time of Arrival: 27-11-2018 14:15:00

Rectification Time: 27-11-2018 14:30:00

Time of Departure: 27-11-2018 14:30:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Noisy

For Lift(s): L3

For Floor(s):

Call Description: Reported loud grinding noise coming from office tower lift.

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Noise coming from sheave undercarriage need second person to lubricate

Part Required: No Parts Required

Service Technician

Matt Grieger

Report Customer