



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

**Box Hill Library**  
1038 Whitehorse Rd Box Hill  
Contract No: 3471 - B076

**Callouts: 22160**

Date of Call: 01-11-2018 10:48:18  
Time of Arrival: 01-11-2018 11:20:00  
Rectification Time: 01-11-2018 12:00:00  
Time of Departure: 01-11-2018 12:20:00

#### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** S.W.P

**For Lift(s):** 1

**For Floor(s):** 1

**Call Description:** SWP

**Order Number:** 125730

#### DESCRIPTION OF WORK

**Fault Found (CAUSE):** See Work Description

**Work Action (CORRECTION):** See Work description

**Work Description:** Lift was running on arrival \r\nLift had stopped out of level going from g to lv1.\r\nFound 2 24v relays associated with slow down arced out. Replaced relays.\r\nAlso clean car top limits and check lock cleanances.

**Part Required:** 2 new relays

**Service Technician**

Zane Tregurtha

**Report Customer**

0