

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 1300161740 info@unitedlifts.com.au

Service Address: Wesley College (557 St Kilda Rd, St Kilda) 557 St Kilda Rd St Kilda Contract No: P3287

Callouts: 22419

Date of Call: 28-11-2018 8:15:00 Time of Arrival: 28-11-2018 9:00:00 Rectification Time: 28-11-2018 9:15:00 Time of Departure: 28-11-2018 10:00:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 3

For Floor(s): .

Call Description: lift is stuck on the ground floor

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Door roller sticking on ground floor cleaned and adjusted ran and tested

Part Required: No Parts Required

Service Technician Report Customer

Brad Stellini