

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 1300161740 info@unitedlifts.com.au

Service Address:
Elizabeth St 191, Richmond (Building B)
191 Elizabeth St Richmond (Building B)
Contract No: P3547

Callouts ID:

Date of Call: 19-10-2018 19:17:00 Time of Arrival: 19-10-2018 21:50:00 Rectification Time: 19-10-2018 22:45:00 Time of Departure: 19-10-2018 22:45:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): 6

Call Description: Ooo

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): Faulty Brakes

Work Action (CORRECTION): See Work description

Work Description: Ooo above top floor\r\nError 54 brake on overtime\r\nFound brake not dropping smoothly and evenly\r\nOne side intermittently sticking\r\nS down as needs to have brake stripped and cleaned

Part Required: No Parts Required

Service Technician

Report Customer

Matt Grieger