



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
03 9687 9099
info@unitedlifts.com.au

Customer Details:

Victoria House
220 Clarendon St East Melbourne
Contract No: 3540

Maintenance:

Date of Call: 21-12-2018
Time of Arrival: 14:15:00
Time of Departure: 14:45:00

Maintenance Details

Maintenance Description: Routine maintenance

Maintenance Task	1
Contact Building Rep. Check Ride & Appointments.	Y
Test all car safties	Y
Clean & Check all M/R Equipment	Y
Clean out controller ad check operation of various parts.	Y
Check car door operator and associated equipment.	Y
Clean & check landing door equipment	Y
Check pit equipment and check water for pit	Y
Check hydrolic tank oil level, valves RAM etc	Y
Test Emergency Light Unit	Y
Test Lift Communications	Y

Service Technician

Nathan Downton

Customer Email

jessicah@selectocm.com.au;whitesteelemgt@selectocm.com.au