



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

Centre for Adult Education / Flinders Lane City Library  
253 Flinders Lane Melbourne  
Contract No: P3388

**Callouts ID: 22101**

Date of Call: 25-10-2018 12:47:39  
Time of Arrival: 25-10-2018 13:00:00  
Rectification Time: 25-10-2018 19:20:00  
Time of Departure: 25-10-2018 19:24:00

#### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** S.W.P

**For Lift(s):** 2

**For Floor(s):** 2

**Call Description:** person stuck in lift on left 2\r\nDave 0416 921 884

**Order Number:** x

#### DESCRIPTION OF WORK

**Fault Found (CAUSE):** Faulty Relay

**Work Action (CORRECTION):** See Work description

**Work Description:** Refer below

**Part Required:** Faulty SC and DPR relays to be replaaced

**Service Technician**

Graeme Gathercole

**Report Customer**

Dave 0416 921 884