

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 1300161740 info@unitedlifts.com.au

Service Address:

Metro Dandenong

Metro Foster Street Dandenong

Contract No: W3677

Callouts:

Date of Call: 06-11-2018 19:57:00 Time of Arrival: 06-11-2018 21:20:00 Rectification Time: 06-11-2018 21:25:00 Time of Departure: 06-11-2018 21:55:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 2

For Floor(s): g

Call Description: Ooo doors open

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): Error Log Fault

Work Action (CORRECTION): Adjust Doors/Locks

Work Description: Error 54 \r\nCheck door tracks and door shoes\r\nTighten all shoes has some had come loose\r\nTest ok\r\nCalled out to another job whilst te

Part Required: No Parts Required

Service Technician

Report Customer

Matt Grieger