

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 1300161740 info@unitedlifts.com.au

Service Address:

Metro Laverton

Metro Laverton Station Laverton

Contract No: P3587

## Callouts ID: 22063

Date of Call: 22-10-2018 11:34:23 Time of Arrival: 22-10-2018 11:50:00 Rectification Time: 22-10-2018 12:00:00 Time of Departure: 22-10-2018 12:00:00

## CALLOUTS DETAILS

Reported Fault (COMPLAINT): S.W.P

For Lift(s): Lift 1,Lift 2,Lift 3,Lift 4

For Floor(s): g

**Call Description: SWP** 

Order Number: 02AA599779

## **DESCRIPTION OF WORK**

Fault Found (CAUSE): Power Failure

Work Action (CORRECTION): See Work description

Work Description: Fire brigade got passenger out on arrival\r\nPower failure all lifts and station no power

Part Required: No Parts Required

Service Technician

**Report Customer** 

Matt Grieger