



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Queen St 221, Melbourne
221 Queen St Melbourne
Contract No: P3387

Callouts ID: 21991

Date of Call: 15-10-2018 11:41:10
Time of Arrival: 15-10-2018 15:20:00
Rectification Time: 15-10-2018 15:45:00
Time of Departure: 22-10-2018 16:10:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Doors Open

For Lift(s): 1

For Floor(s): G

Call Description: stuck on ground floor with doors open

Order Number: Nil

DESCRIPTION OF WORK

Fault Found (CAUSE): Door Lock Faulty

Work Action (CORRECTION): Adjust Doors/Locks

Work Description: Lift 000 on G. Lock fault on controller, adjust level G landing doors and clean objects from door track. \r\nRan to test. Ok.

Part Required: No Parts Required

Service Technician

James Grey

Report Customer

Jimmy 94217087