



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Queen St 341

341 Queen Street Melbourne

Contract No: P3719

Callouts:

Date of Call: 29-11-2018 7:00:00

Time of Arrival: 29-11-2018 7:00:00

Rectification Time: 29-11-2018 9:55:00

Time of Departure: 29-11-2018 9:55:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): See Fault Description

For Lift(s): 1

For Floor(s): All

Call Description: Follow up

Order Number: Nil

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Follow up from previous callouts. Change CB contactor and checked operation of all contacts. Check brake operation and ran lift to monitor.

Part Required: No Parts Required

Service Technician

James Grey

Report Customer

BM