



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
03 9687 9099
info@unitedlifts.com.au

Customer Details:

Caulfield Park Pavilion

280 Balaclava Rd Caulfield

Contract No: P3399

Maintenance:

Date of Call: 04-12-2018
Time of Arrival: 12:40:00
Time of Departure: 13:19:00

Maintenance Details

Maintenance Description: Routine maintenance

Maintenance Task	1
Contact Building Rep. Check Ride & Appointments.	Y
Test all car safeties	Y
Clean & Check all M/R Equipment	Y
Clean out controller ad check operation of various parts.	Y
Check tuning adjustments	Y
Check car door operator and associated equipment.	Y
Clean & check landing door equipment	Y
Check car top safeties, Ropes, Inductors Lubricate Rails Etc.	Y
Check and adjust car & cwt guide shoes	Y
Check all safety switches, limits in lift well	Y
Check pit equipment and check water for pit	Y
Check trailer flexes, attachments running clearance	Y
Check hydrolic tank oil level, valves RAM etc	Y
Test Lift Communications	Y

Service Technician

Kevin Wilkins

Customer Email

DHipshe@gleneira.vic.gov.au