



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Riggall St 61

61 Riggall Street Broadmeadows

Contract No: P3608

Callouts: 22136

Date of Call: 30-10-2018 12:17:44

Time of Arrival: 30-10-2018 13:30:00

Rectification Time: 30-10-2018 14:20:00

Time of Departure: 30-10-2018 14:30:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): 6

Call Description: no lights in smaller lift in 6th storey building. when call button is pressed, only the bigger lift responds

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): Faulty Brakes

Work Action (CORRECTION): See Work description

Work Description: Clean contacts in brake cct. Strip and lubricate brake plungers.

Part Required: No Parts Required

Service Technician

mat tehan

Report Customer

.