



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

**Metro Dandenong**  
Metro Foster Street Dandenong  
Contract No: W3677

**Callouts: 22169**

Date of Call: 02-11-2018 14:37:37  
Time of Arrival: 02-11-2018 15:34:00  
Rectification Time: 02-11-2018 16:25:00  
Time of Departure: 02-11-2018 16:35:00

#### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** O.O.O

**For Lift(s):** 1

**For Floor(s):** 1

**Call Description:** lift is stuck on platform level

**Order Number:** 658429

#### DESCRIPTION OF WORK

**Fault Found (CAUSE):** See Work Description

**Work Action (CORRECTION):** See Work description

**Work Description:** Lift had error 54 door lock fault on platform level.  
Vac tracks out; check door operation and latching locl. Check car veins.  
Ran and test lift ok.

**Part Required:** No Parts Required

**Service Technician**

Zane Tregurtha

**Report Customer**

0