



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

King St 27, Prahran
27 King St Prahran
Contract No: P3433

Callouts:

Date of Call: 09-12-2018 22:10:00
Time of Arrival: 09-12-2018 22:50:00
Rectification Time: 09-12-2018 23:50:00
Time of Departure: 09-12-2018 23:55:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 2

For Floor(s): 6

Call Description: out of order

Order Number: 15999

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: lift on level 6,\r\ndoors closed out of group,\r\nsuspect faulty leveling sensors cleaned and checked operation tested ok.

Part Required: No Parts Required

Service Technician

Robert Pelle

Report Customer

jayden