



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
03 9687 9099
info@unitedlifts.com.au

Customer Details:

Cambridge Street 21
21 Cambridge Street Box Hill
Contract No: B3675

Maintenance:

Date of Call: 13-11-2018
Time of Arrival: 14:50:00
Time of Departure: 15:50:00

Maintenance Details

Maintenance Description: Regular service \r\nReplace failed light \r\nVac car top and door tracks

Maintenance Task	1
Contact Building Rep. Check Ride & Appointments.	
Test all car safties	
Clean & Check all M/R Equipment	
Clean out controller ad check operation of various parts.	
Check tuning ajustments	
Check car door operator and associated equipment.	
Clean & check landing door equipment	
Check car top safeties, Ropes, Inductors Lubricate Rails Etc.	
Check and ajust car & cwt guide shoes	
check brake operation rope brake and associated equipment	
Check pit equipment and check water for pit	
Test Emergency Light Unit	
Test Lift Communications	

Service Technician

Zane Tregurtha

Customer Email

EllyesM@rosshunt.com.au