



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

35-41 Argyle St  
35-41 Argyle Street Fitzroy  
Contract No: P3690

## Callouts ID:

Date of Call: 18-10-2018 17:30:00  
Time of Arrival: 18-10-2018 18:10:00  
Rectification Time: 18-10-2018 18:45:00  
Time of Departure: 18-10-2018 18:57:00

### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** O.O.O

**For Lift(s):**

**For Floor(s):** 3

**Call Description:** Lift o.o.o doors open level 3.

**Order Number:** \*

### DESCRIPTION OF WORK

**Fault Found (CAUSE):** See Work Description

**Work Action (CORRECTION):** Clean Light Ray

**Work Description:** Doors unable to close. Light rays dirty, cleaned and returned to service. Monitored, tested ok.

**Part Required:** No Parts Required

**Service Technician**

Nathan Downton

**Report Customer**

\*