

Customer Details:

Metro Box Hill

Metro Box Hill Station Box Hill

Contract No: P3581

Maintenance:

Date of Call: 31-03-2019

Time of Arrival: 0:00:00

Time of Departure: 0:00:00

Maintenance Details

Maintenance Description: not finished

Lift Name	Escalator 1
Contact Building Rep /Client	Y
Erect barricades and place signage in visible location	Y
Test Escalator ride quality	Y
Test Escalator stopping distance when stop button depressed	Y
Open machine hatches and test Stop buttons for safe access	Y
Clean/Vacuum machine room and pit removing dust and debris	Y
Inspect brake and brake lining and adjust if required	Y
Inspect tensioning of main drive chain and step chain	Y
Lubricate Main drive chain, step chain and handrail drive chain	Y
Lubricate step rollers for smooth ride quality	Y
Inspect handrail condition for pinch points or wear	Y
Clean and lubricate handrail Newel rollers	Y
Check clearances between steps and skirt clearances	Y
Check clearances between steps	Y

Lift Name	Escalator 2
Inspect tensioning of main drive chain and step chain	Y
Lubricate Main drive chain, step chain and handrail drive chain	Y
Lubricate step rollers for smooth ride quality	Y
Inspect handrail condition for pinch points or wear	Y
Clean and lubricate handrail Newel rollers	Y
Check clearances between steps and skirt clearances	Y
Check clearances between steps	Y

Check condition of combplates	Y
Check operation of Combplate safety switches	Y
Check operation of tension carriage safety swiches and tolerances	Y
Check operation of stop buttons in machine room and pit	Y
Check operation of Stop buttons on skirting and bollards	Y
Inspect lubrication system and maintain	Y
Check Direction Indicators	Y
Check Understep lighting operation	Y

Service Technician Volkan

Customer Email

[Thanks for choosing United Lifts Services! 24 Hour Service. Phone 1300161740](#)
