



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Punt Hill - Chadstone Gateway (1384 Dandenong Rd, Oakleigh)
1384 Dandenong Rd Oakleigh
Contract No: P3292

Callouts: 22687

Date of Call: 21-12-2018 12:44:31
Time of Arrival: 21-12-2018 13:30:00
Rectification Time: 21-12-2018 13:45:00
Time of Departure: 21-12-2018 13:45:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): 2

Call Description: stuck on the second floor

Order Number: 0

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Light rays preventing doors from closing. \r\nClean and tighten connections and doors closed. Will monitor and replace if issue occurs again.

Part Required: No Parts Required

Service Technician

Zane Tregurtha

Report Customer

sARA 90387575