



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

King St 27, Prahran
27 King St Prahran
Contract No: P3433

Callouts:

Date of Call: 02-12-2018 16:05:00
Time of Arrival: 02-12-2018 16:37:00
Rectification Time: 02-12-2018 17:11:00
Time of Departure: 02-12-2018 17:35:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Not Stopping Level

For Lift(s): 2

For Floor(s): G

Call Description: Not stopping level

Order Number: 15860

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Found ground floor to be out of level. Adjusted floor magnet to allow for proper levelling. Also checked and adjusted tape head guides for correct function. Run and tested. Returned to service

Part Required: No Parts Required

Service Technician

James Wallace

Report Customer

.