



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Kingsgate Hotel
131 King St Melbourne
Contract No: P3249

Callouts: 22555

Date of Call: 11-12-2018 10:33:25
Time of Arrival: 11-12-2018 12:25:00
Rectification Time: 11-12-2018 13:30:00
Time of Departure: 11-12-2018 13:45:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 2

For Floor(s): 2

Call Description: out of order on level 2

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: lift out of order on level 5 replaced \r\nfaulty KAD relay checked operation ok.

Part Required: 110vac 50hz 5.5kw Siemens relay.

Service Technician

Robert Pelle

Report Customer

Yash 0396294171